



City of South Daytona Bid Addendum

Bid Number:	23-013
Bid Title:	Reed Canal Pump Installation
Bid Opening Date:	2:00 P.M. on Thursday, June 1, 2023
Bid Addendum Number:	1
Bid Addendum Date:	May 17, 2023

*Questions Received. Answered from the City of South Daytona are in **RED**.*

1. What is the engineers estimate for this project? ***\$135,000***
2. The line service riser diagram shows a 100A double throw disconnect switch, but the detail below the diagram calls out for a main breaker in an enclosure....please clarify which is required.
The double throw switch should be fused, if a fused switch is unavailable, a main breaker will be required.
3. Is there a specific dimension for the service gutter? Will it need to accommodate future equipment?
No specific size is required for the service gutter, it must be large enough to accommodate the installed equipment.
4. How wide will the equipment rack need to be? Will it need to accommodate future equipment?
The equipment rack does not require a specific dimension, no future equipment is known at this time.
5. Please provide more information on the "Z CHANNEL FOR GATE" detail, noted on sheet 4 of 5 in the EMBANKMENT AND STRUCTURE PROFILE VIEW. Is there an actual "gate"? If so, will The City be installing and/or providing?
The City is requesting coordination with the successful bidder on the most appropriate size and design of the manual slide gate on the intake side of the box.